



1 Procedure for Installation of Remote Keypad Mounting Kit for UL Type 1, Type 12, Type 3R, and IP55 Enclosures




2 Compatible Products

This installation kit is compatible with keypad models JVOP-KPLxxxxxx. Please refer to the Installation Manual packaged with the drive or keypad when you install this option.

3 Collect the Required Tools and Equipment



4 Make Sure the Kit Will Fit in the Desired Location



NOTICE Measure the printed dimensions before you drill the screw holes. Moisture can cause the template scale to change.


⚠ DANGER Electrical Shock Hazard. Do not connect or disconnect wiring while the power is on. Failure to comply will result in death or serious injury. Before servicing, disconnect all power to the equipment. The internal capacitor remains charged even after the power supply is turned off. The charge indicator LED will extinguish when the DC bus voltage is below 50 Vdc. To prevent electric shock, wait for at least the time specified on the warning label, once all indicators are OFF, measure for unsafe voltages to confirm the drive is safe prior to servicing. Failure to comply will result in death or serious injury.

5 Cut the Opening

Use the measurements above or the template in **A** to cut the opening and drill or punch 6 each ø6 holes on the customer-supplied enclosure.


6 Snap-fit the Keypad (Not Included) into the Keypad Kit Subassembly

You can also use the provided M3 x 6 flat head screws and tighten to 0.49 to 0.73 N·m (4.3 to 6.4 in·lb) for additional security.



7 Attach the Keypad Kit Subassembly to the Enclosure

Use the provided M5 flange nuts and tighten the screws in the order shown below with initial torque. Gradually increase the torque to 2 to 2.5 N·m (17.1 to 22.1 in·lb) to evenly compress the gasket.




8 Select the Keypad Cable

Select the customer-supplied keypad cable length best suited for the enclosure size. Plug one end of the cable into the female connector on the back side of the keypad. Plug the other end of the cable into the female connector on the front of the drive. The location of the connector is different for different drive models.

9 Safety the Cable to the Subassembly


Either use a cable tie to connect the keypad cable to the loop on the subassembly or put the keypad cable into the snap fit connector on the subassembly.

Protect the cable from sharp edges and make sure that the cable does not pinch in the enclosure door.



A - Cable tie to loop
B - Use snap fit

10 Make Sure that the Cover Latch Functions Correctly



A - To close: Push both triangles on this side (2 clicks necessary)
B - To open: Push both triangles on this side (2 clicks necessary)

11 Test the Keypad


Apply main power to the drive and make sure that the keypad functions correctly. Refer to the keypad installation manual or the drive installation manual for more information.

WARNING Sudden Movement Hazard. Remove all personnel and objects from the area around the drive, motor, and machine and attach covers, couplings, shaft keys, and machine loads before you energize the drive. If personnel are too close or if there are missing parts, it can cause serious injury or death.



A Drilling and Cutting Template (1:1 Scale)

NOTICE Measure the printed dimensions before you drill the screw holes. Moisture can cause the template scale to change.



YASKAWA AC Drive Option
Remote Keypad Mounting Kit
For UL Type 1/Type 12/Type 3R/IP55 Enclosures
Instruction Manual

DRIVE CENTER (INVERTER PLANT)
2-13-1, Nishimiyachi, Yukuhashi, Fukuoka,
824-8511, Japan
Phone: +81-930-25-2548 Fax: +81-930-25-3431
www.yaskawa.co.jp

YASKAWA ELECTRIC CORPORATION
New Pier 1bashiwa South Tower, 1-15-1, Klagan,
Minato-ku, Tokyo, 105-6501, Japan
Phone: +81-3-5402-4502 Fax: +81-3-5402-4580
www.yaskawa.co.jp

YASKAWA AMERICA, INC.
2121, Norman Drive South, Waukegan, IL 60085, U.S.A.
Phone: +1-800-YASKAWA (927-5292) or +1-847-887-7000
Fax: +1-847-887-7310
www.yaskawa.com

YASKAWA ELETRICO DO BRASIL LTDA.
777, Avenida Piraporinha, Diadema, São Paulo,
09950-000, Brazil
Phone: +55-11-3585-1100 Fax: +55-11-3585-1187
www.yaskawa.com.br

YASKAWA EUROPE GmbH
Hauptstraße 185, 85700 Eschborn, Germany
Phone: +49-6196-569-300 Fax: +49-6196-569-398
www.yaskawa.eu.com
E-mail: info@yaskawa.eu.com

YASKAWA ELECTRIC KOREA CORPORATION
35F, Three IFC, 10 Gukgeumyungno,
Yongdeung-gu, Seoul, 07258, Korea
Phone: +82-2-784-7944 Fax: +82-2-784-8495
www.yaskawa.co.kr

YASKAWA ASIA PACIFIC PTE. LTD.
30A, Kallang Place, #06-01, 339213, Singapore
Phone: +65-6283-3003 Fax: +65-6289-3503
www.yaskawa.com.sg

YASKAWA ELECTRIC (THAILAND) CO., LTD.
59, 1F-5F, Flouish Building, Soi Ratchasapaeak 18,
Ratchasapaeak Road, Huaykwang, Bangkok, 10310,
Thailand
Phone: +66-2-017-4099 Fax: +66-2-017-0799
www.yaskawa.co.th

YASKAWA ELECTRIC (CHINA) CO., LTD.
22F, Link Square 1, No.222, Hubin Road, Shanghai,
200021, China
Phone: +86-21-5385-2200 Fax: +86-21-5385-3299
www.yaskawa.com.cn

YASKAWA ELECTRIC (CHINA) CO., LTD. BEIJING OFFICE
Room 1011, Tower W3 Oriental Plaza, No. 1,
East Cheng An Avenue,
Dong Cheng District, Beijing, 100738, China
Phone: +86-10-8518-4086 Fax: +86-10-8518-4082


YASKAWA ELECTRIC TAIWAN CORPORATION
12F, No. 207, Section 3, Beishin Road, Shindian District,
New Taipei City 21143, Taiwan
Phone: +886-2-8913-1333
Fax: +886-2-8913-1513 or +886-2-8913-1519
www.yaskawa.com.tw

YASKAWA INDIA PRIVATE LIMITED
#17A, Electronics City, Hosur Road, Bengaluru,
560 100 (Karnataka), India
Phone: +91-80-4244-1900 Fax: +91-80-4244-1901
www.yaskawaindia.in

YASKAWA

YASKAWA AC Drive Option
Remote Keypad Mounting Kit
For UL Type 1/Type 12/Type 3R/IP55 Enclosures
Instruction Manual
Model: 900-239-230-001

To properly use the product, read this manual thoroughly and retain for easy reference, inspection, and maintenance. Ensure the end user receives this manual.



YASKAWA

YASKAWA ELECTRIC CORPORATION

In the event that the end user of this product is to be the military and said product is to be employed in any weapons systems or the manufacture thereof, the export will fall under the relevant regulations as stipulated in the Foreign Exchange and Foreign Trade Regulations. Therefore, be sure to follow all procedures and submit all relevant documentation according to any and all rules, regulations and laws that may apply. Specifications are subject to change without notice for ongoing product modifications and improvements.

© 2019 YASKAWA ELECTRIC CORPORATION



TOEPC72060013

MANUAL NO. TOEP C720600 13C <2>-0
Published in Japan March 2020
20-0-22